

















RROG meeting 2019

Report on LVR-15 and LR-0 reactors (CZ)

Vlastimil Juricek


Mainz, May 14 – 17

Reactors LVR-15 and LR-0



- Operated by Research Centre Rez
 - LVR-15 operated from 1957, fuel converted 2011 (IRT-2M -> IRT-4M)
 - LR-0 in operation from 1982, converted from birth
 - Both having operating license till December 2020








Research reactor LVR-15



| Reactor type | tank | |
|------------------------|------------------------|--------|
| Pressure | atmospheric | |
| Average temperature | 45 | °C |
| Coolant | demineralized water | |
| Reflector | beryllium | |
| Nominal power | 10 | MWt |
| Thermal flux in n-trap | 1.5 x 10 ¹⁴ | n/cm²s |
| Fast flux in fuel | 2.5 x 10 ¹⁴ | n/cm²s |





LR-0 experimental reactor



- The light water zero power reactor
- Reactor with versatile core arrangements
- For determination of neutron-physical characteristics of various types of reactor lattices, kinetics experiments
- Reactor ionization chambers and other I&C equipment testing
- Experiments with various insertion zone types (graphite, fluorine salts, heavy water)
- Experimental verification of criticality and subcriticality in relation to core parameters
- Verification of neutronic codes/libraries





Utilization in 2018




- LVR-15:
 - 168.9 operational days (39421 MWh)
 - 1 unplanned shutdown (0.75 day, ext. power failure)
 - Utilization for horizontal channels (neutron radiography, difractometry, scattering and depth profiling)
 - Radionuclide production (Mo99, Ho166, Co60, ...)
 - Neutron doping (Silicon, Topaz)
 - Material testing in irradiation rigs



Utilization in 2018



- LR-0:
 - 268 operational hours (84 day shifts)
 - 0 unplanned shutdowns
 - Utilization for research of reactor physics
 - Reaction rate measurement for various neutron reactions, e.g. Na23(n,2n)
 - neutron spectrum measurements in graphite, fluoride & lead insertions





Safety performance indicators in 2018



| Year | | | 2015 | 2018 |
|---|--|---|--------|-------|
| | | | | |
| D1(a) | Collective radiation dose to Reactor Operations Staff (mSv) | | 43,91 | 44,83 |
| D1(b) | Number of Reactor Operations Staff | | 28 | 28 |
| D1(c) | D1(a)/D1(b) (mSv/man) | | 1,57 | 1,60 |
| D2(a) | Collective radiation dose to all staff from reactor related work (mSv) | | 134,26 | 88,56 |
| D2(b) | Total number of staff involved | | 101 | 106 |
| D2(c) | D2(a)/D2(b) (mSv/man) | | 1,33 | 0,84 |
| | | | | |
| E1 | Rare Gas released to atmosphere [TBq] | | 51,60 | 49,20 |
| E2 | Tritium released to atmosphere [TBq] | * | 0,46 | 0,34 |
| E3 | Tritium water discharge [GBq] | * | 1,77 | 0 |
| E4 | lodine released to atmosphere [MBq] | * | 29,10 | 11,60 |
| | | | | |
| * all workplaces with radionuclides in area | | | | |



Activities in 2019



- Extended maintenance planned in September November
 - LVR-15 Radiation monitoring system
 - LVR-15 Secondary heat exchangers
 - LVR-15 Primary coolant system instrumentation (flow, pressure, level, temperatures)
 - LVR-15 & LR-0 Neutron detectors
 - LVR-15 Absorbers
- Finalizing harmonization of reactor documentation (new Czech Atomic Act from 2017)
 - Updated SAR, OLC, AMP, ...
 - Newly created SAMGs
- Preparation of new license application
 - INSARR (preINSARR invited for July), PSR

Inspections and Aging Management



- Inspections and maintenance plan approved by regulator (updated in 2019)
 - Longest period inspections (5years) focus on reactor vessel, internals and primary cooling system
 - Last performed in 2017, indicated good shape of the critical components with prediction to 2028 at least
- Aging management program was in till 2018 based on inspections without defining degradation mechanisms, methods and criteria to estimate residual lifetimes – the update in 2019 follows the IAEA guidelines. Monitored SSC were defined, currently building the first data

Decommissioning



- Both reactors have an updated decommissioning program pending for authorization (updated regulerly each 5 years)
 - Important addition is the safety assessment supporting the emergency planning for the decommissioning phase
- The reserve fund is continuously filled as planned (for decommissioning in 2028)
 - Complication is the historical changes in ownership/utilization of the reactors
 - till 1994 state owned and operated
 - 1994 2010 operated by private company UJV
 - Since 2011 operated by Research Centre (daughter company of UJV)





Thank for your attention

Contact:

Vlastimil.Juricek@cvrez.cz

